

ORDINANCE NO. 2021-05

AN ORDINANCE AMENDING SECTION 3 OF ORDINANCE NO. 944 OF 1984 REGULATING SERVICE ENTRANCES

WHEREAS, there is a need to amend the requirements for service entrances of structures utilizing electrical service in the City of Malvern to require residential services that are upgraded to include the addition of smoke detectors.

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF MALVERN AS FOLLOWS:


Section 1. That Section 3 of Ordinance No. 944, adopted 1984 be amended to read as follows:

Section 3: All service entrances must be of rigid conduits, E.M. tubing or rigid P.V.C. and must continue to the main distribution panel. If the main distribution panel is located other than outside, then a main breaker disconnect will be installed on the outside of the building. Temporary meter loops for use in construction etc., will meet code requirements as specified for new construction. When a residential service is upgraded, smoke detectors will be installed in accordance with NFPA 72.

Section 2. That all ordinances and part of ordinances in conflict herewith are hereby repealed.

Passed this 10th day of May, 2021.

APPROVED:



Brenda J. Weldon, Mayor

ATTEST:



Phyllis Dial, City Clerk

