WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

October 2015

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	**78,283,000**	**708,020,000**
Backwash / Gallons:	**2,387,000**	**21,177,464**
Backwash (Number of Filters):	**31**	**307**
Actiflow Flushing / Gallons:	**10,600**	**106,000**
Daily Laboratory Test / Reports (Number):	**930**	**9,120**
Pump Station Check	**217**	**2,128**
Pump Station Maintenance	**8**	**80**
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	**180**	**1,569**
Coagulant Used / LBS.	**5,468**	**52,219**
Polymer Used / LBS.	**67**	**646**
Silica Sand Used / LBS.	**450**	**9,000**
Filter Aid Used	**776**	**7,013**
Caustic Used / LBS.	**5,525**	**64,945**
Chlorine Used / LBS.	**19,037**	**152,803**
Fluoride Used / LBS.	**2,794**	**25,242**
Orthophosphate Used / LBS.	**1,187**	**10,727**

Comments: