WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

January 2016

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	**68,194,000**	**68,194,000**
Backwash / Gallons:	**2,387,000**	**2,387,000**
Backwash (Number of Filters):	**31**	**31**
Actiflow Flushing / Gallons:	**10,600**	**10,600**
Daily Laboratory Test / Reports (Number):	**930**	**930**
Pump Station Check	**217**	**217**
Pump Station Maintenance	**8**	**8**
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	**159**	**159**
Coagulant Used / LBS.	**5,301**	**5,301**
Polymer Used / LBS.	**90**	**90**
Silica Sand Used / LBS.	**600**	**600**
Filter Aid Used	**677**	**677**
Caustic Used / LBS.	**7,311**	**7,311**
Chlorine Used / LBS.	**12,513**	**12,513**
Fluoride Used / LBS.	**2,438**	**2,438**
Orthophosphate Used / LBS.	**1,036**	**1,036**

Comments: