WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

April 2016

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	**65,191,000**	**258,431,000**
Backwash / Gallons:	**2,310,000**	**9,317,000**
Backwash (Number of Filters):	**30**	**121**
Actiflow Flushing / Gallons:	**10,600**	**42,400**
Daily Laboratory Test / Reports (Number):	**900**	**3,630**
Pump Station Check	**210**	**847**
Pump Station Maintenance	**8**	**32**
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	**152**	**642**
Coagulant Used / LBS.	**4,822**	**19,444**
Polymer Used / LBS.	**60**	**260**
Silica Sand Used / LBS.	**1,500**	**2,850**
Filter Aid Used	**649**	**2,574**
Caustic Used / LBS.	**5,243**	**23,141**
Chlorine Used / LBS.	**13,710**	**50,649**
Fluoride Used / LBS.	**2,336**	**9,266**
Orthophosphate Used / LBS.	**993**	**3,938**

Comments: