WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

August 2016

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	71,547,000	547,807,000
Backwash / Gallons:	2,387,000	19,250,000
Backwash (Number of Filters):	31	250
Actiflow Flushing / Gallons:	10,600	84,800
Daily Laboratory Test / Reports (Number):	930	7,320
Pump Station Check	217	1,708
Pump Station Maintenance	8	64
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	199	1,426
Coagulant Used / LBS.	5,405	42,533
Polymer Used / LBS.	61	535
Silica Sand Used / LBS.	750	5,850
Filter Aid Used	856	5,368
Caustic Used / LBS.	10,807	59,077
Chlorine Used / LBS.	19,933	116,745
Fluoride Used / LBS.	2,504	19,550
Orthophosphate Used / LBS.	1,086	8,331

Comments: