WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

July 2015

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	**74,089,000**	**470,917,000**
Backwash / Gallons:	**2,387,000**	**14,093,464**
Backwash (Number of Filters):	**31**	**215**
Actiflow Flushing / Gallons:	**10,600**	**74,200**
Daily Laboratory Test / Reports (Number):	**930**	**6,360**
Pump Station Check	**217**	**1,484**
Pump Station Maintenance	**8**	**56**
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	**170**	**1,024**
Coagulant Used / LBS.	**5,564**	**34,735**
Polymer Used / LBS.	**74**	**445**
Silica Sand Used / LBS.		**7,350**
Filter Aid Used	**734**	**4,663**
Caustic Used / LBS.	**7,152**	**45,278**
Chlorine Used / LBS.	**16,188**	**94,920**
Fluoride Used / LBS.	**2,642**	**16,786**
Orthophosphate Used / LBS.	**1,123**	**7,134**

Comments: