WATER TREATMENT PLANT WORK ACCOMPLISHMENT REPORT

August 2015

SUPERVISOR : Terry Littles

ITEM	CURRENT MONTH	YEAR-TO-DATE
Water Produced / Gallons:	80,067,000	550,984,000
Backwash / Gallons:	2,387,000	16,480,464
Backwash (Number of Filters):	31	246
Actiflow Flushing / Gallons:	10,600	84,800
Daily Laboratory Test / Reports (Number):	930	7,290
Pump Station Check	217	1,701
Pump Station Maintenance	8	64
Chemicals Used	Chemicals Used	
Permanginate Used / LBS.	205	1,229
Coagulant Used / LBS.	6,041	40,776
Polymer Used / LBS.	69	514
Silica Sand Used / LBS.	300	7,650
Filter Aid Used	793	5,456
Caustic Used / LBS.	7,466	52,744
Chlorine Used / LBS.	20,188	115,108
Fluoride Used / LBS.	2,853	19,639
Orthophosphate Used / LBS.	1,212	8,346

Comments: